



Emerson Automation Solutions
Actuation Technologies
19200 Northwest Freeway
Houston, Texas 77065
USA

Attestation of Conformity: IEC 60529:1989/AMD2:2013/COR1:2019 – Degree of protection IP66/IP67M

Manufacturer: Emerson Automation Solutions

Product type: Pneumatic Actuators

Model Reference: Bettis G Series and Biffi FG Series spring return and double acting actuators

Series: G, FG

Models: G01, G2, G3, G4, G5, G7, G8, G10, G13 and GC, GH, GHC models; FG01, FG2, FG3, FG4, FG5, FG7, FG8, FG10, FG13 and FGC, FGH, FGHC models

Test Laboratory: SGS-CSTC Standards Technical Service (Tianjin) Co., Ltd.
SGS Mansion, No.41, The 5th Avenue TEDA, Tianjin, China 300457

SGS Test Report No: RSTSTJ220629000101 for Double Acting Actuator
RSTSTJ220629000201 for Spring Return Actuator

Requirements: IP66 / IP67M Dust and Water Ingress Protection test per IEC 60529:1989/AMD2:2013/COR1:2019

Emerson Automation Solutions declares the above-described products meet the above-mentioned technical specification. This attestation of conformity is issued based on the test results as laid down in the SGS Test Reports referenced above where two representative actuators were independently observed to meet the IP66/ 67M criteria. The actuators tested are representative of the entire range of the Bettis G, GH and Biffi FG, FGH series by common parts or common design philosophy and by simple scalability. All vent ports must be protected using environmental piping or piped to a protected location

Date of Issue: 12-Jul-2023

Toni Zhang

Product Manager,
Bettis Scotch Yoke

Massimiliano Franco

Product Manager,
Biffi Scotch Yoke