



**Certificate no. TAI-FS-C-22-0046**

WE HEREBY CERTIFY THAT

**Product description** HYDRAULIC LINEAR SPRING RETURN AND DOUBLE ACTING ACTUATOR

**Models** SERIES HLAS, HLDAS, HLA, HLDA

**Manufacturer** BIFFI ITALIA S.r.l.  
Strada Biffi 165  
I-29017 Fiorenzuola d'Arda (PC)

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

**IEC 61508 Parts 1–7:2010**

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION SET OUT IN THE ABOVE-MENTIONED STANDARDS

**Summary Report no. TAI-FS-R-22-0093**

**Expiry date 25.09.2025**

**Issue date 26.09.2022**

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.  
26.09.2022, Monte Roberto (AN)

Page 1 of 2

Ing. Crescenzo Di Fratta

## Annex to certificate no. TAI-FS-C-22-0046


<b>Type</b>	A
<b>HFT</b>	0
<b>Safety functions</b>	<u>Spring return actuators:</u> 1. Delivery of a full stroke ( $90^\circ \pm$ tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system <u>Double acting actuators:</u> 1. Delivery of a full stroke ( $90^\circ \pm$ tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
<b>Mode of operation</b>	Low Demand Mode

Random failure rates				
Configuration	Safety function	$\lambda_{DU}$ [1/h]	$\lambda_{DD}$ [1/h]	$\lambda_S$ [1/h]
HLAS - No PST	1	1,29E-08	0,00E+00	0,00E+00
HLAS - With PST	1	1,16E-09	1,18E-08	0,00E+00
HLDAS - No PST	1	1,31E-08	0,00E+00	0,00E+00
HLDAS - With PST	1	1,18E-09	1,20E-08	0,00E+00
HLA - No PST	1	1,40E-08	0,00E+00	0,00E+00
HLA - With PST	1	1,26E-09	1,27E-08	0,00E+00
HLDA - No PST	1	1,40E-08	0,00E+00	0,00E+00
HLDA - With PST	1	1,26E-09	1,27E-08	0,00E+00

<b>Systematic capability</b>	3 (Route 1s applied)			
<b>Architectural constraints</b>	<b>Route 1<sub>H</sub>:</b>	Applied	<b>Route 2<sub>H</sub>:</b>	Applied
	The product can be used in: <ul style="list-style-type: none"> <li>• single channel configuration:                             <ul style="list-style-type: none"> <li>○ up to SIL 2 without external diagnostic tests</li> <li>○ up to SIL 3 considering external diagnostic tests</li> </ul> </li> <li>• double channel configuration: up to SIL 3</li> </ul>			

- Remarks:**
- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM 026, SM 027

END OF CERTIFICATE



Ing. Crescenzo Di Fratta

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.  
26.09.2022, Monte Roberto (AN)