



Certificate no. TAI-FS-C-23-0032

WE HEREBY CERTIFY THAT

Product description HYDRAULIC SCOTCH-YOKE SPRING RETURN AND DOUBLE ACTING ACTUATOR

Models BIFFI™ SERIES OLGAS, OLGAS-QA, OLGAS-H, OLGA, OLGA-H

Manufacturer BIFFI ITALIA S.r.l.
Strada Biffi 165
I-29017 Fiorenzuola d'Arda (PC)

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. TAI-FS-R-23-0065

Expiry date 01.05.2026

Issue date 02.05.2023

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
02.05.2023, Monte Roberto (AN)

Ing. Crescenzo Di Fratta

Page 1 of 2

Annex to certificate no. TAI-FS-C-23-0032

Type	A
HFT	0
Safety functions	<u>Spring return actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system <u>Double acting actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
OLGAS, OLGAS-H - No PST	1	1,22E-08	0,00E+00	0,00E+00
OLGAS, OLGAS-H - With PST	1	1,10E-09	1,11E-08	0,00E+00
OLGAS-QA - No PST	1	1,32E-08	0,00E+00	0,00E+00
OLGAS-QA - With PST	1	1,19E-09	1,20E-08	0,00E+00
OLGA, OLGA-H - No PST	1	1,37E-08	0,00E+00	0,00E+00
OLGA, OLGA-H - With PST	1	1,23E-09	1,24E-08	0,00E+00

Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1_H:	Applied	Route 2_H:	Applied
	The product can be used in: <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests • double channel configuration: up to SIL 3 			

Remarks:

- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manuals SM 019, SM 003

END OF CERTIFICATE

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
02.05.2023, Monte Roberto (AN)



Ing. Crescenzo Di Fratta